



SCHEDULE 40 GALVANIZED PIPE AND FITTINGS OR SCHEDULE 80 PVC PIPE AND FITTINGS

METER BOX AND LID TO BE FLUSH WITH FINISHED GRADE.

REDUCED PRESSURE VACUUM BREAKER OR REDUCED PRESSURE DEVICE (NOT REQUIRED WHERE RECLAIMED WATER IS UTILIZED)

APPLIES ONLY IF IRRIGATION METER HAS SEPARATE TAP TO MAIN. IN MOST CASES THE IRRIGATION METER WILL BE PARALLEL TO THE HOUSE METER AND OFF OF THE SAME SERVICE CONNECTION.

NOTES:

1. A POSITIVE DIELECTRIC CONNECTION SHALL BE MADE BETWEEN ALL GALVANIZED AND BRASS COMPONENTS.
2. METER SHALL BE INSTALLED BETWEEN SIDEWALK AND CURB WHERE APPLICABLE, OR AT PROPERTY LINE AND IN NO CASE SHALL IT BE INSTALLED IN SIDEWALK OR OTHER PAVED AREAS.
3. USE PRIMER SUITED TO BASE MATERIALS. FINISH WITH TWO COATS OF PURPLE EXTERIOR ENAMEL.
4. DEVICE SHALL BE 12 INCHES (MINIMUM) ABOVE HIGHEST OUTLET.

IRRIGATION METER PRESSURE VACUUM BREAKER OR REDUCED PRESSURE ZONE ASSEMBLY